

LABOR SERVICES DIVISION[875]

Adopted and Filed

Pursuant to the authority of Iowa Code section 89.14, the Boiler and Pressure Vessel Board amends Chapter 91, "General Requirements for All Objects," Iowa Administrative Code.

The amendments update references to the American Society of Mechanical Engineers codes.

The purposes of these amendments are to keep the rules current, protect the safety of the public, and implement legislative intent.

Notice of Intended Action was published in the December 16, 2009, Iowa Administrative Bulletin as **ARC 8391B**. No public comment was received on these amendments. These amendments are identical to those that were published under Notice of Intended Action.

No variance provision is included in these rules. Applicable variance procedures are set forth in 875—Chapter 81.

These amendments are intended to implement Iowa Code chapter 89.

These amendments shall become effective on April 14, 2010.

The following amendments are adopted.

ITEM 1. Amend subrule 91.1(1) as follows:

91.1(1) *ASME boiler and pressure vessel codes adopted by reference.* The ASME Boiler and Pressure Vessel Code (2007 with ~~2008~~ 2008a and 2009b addenda) is adopted by reference. Regulated objects shall be designed and constructed in accordance with the ASME Boiler and Pressure Vessel Code (2007 with ~~2008~~ 2008a and 2009b addenda) except for objects that meet one of the following criteria:

a. to f. No change.

ITEM 2. Amend subrule 91.1(4) as follows:

91.1(4) *Piping codes adopted by reference.* The Power Piping Code, ASME B31.1 (~~2007 with 2008 addenda~~) B31.1 (2007), ASME B31.1a (2008), and ASME B31.1b (2009), and the Building Services Piping Code, ASME B31.9 (2008), are adopted by reference, and reinstallations and installations after ~~January 1, 2010~~ April 14, 2010, shall comply with them up to and including the first valve.

[Filed 2/18/10, effective 4/14/10]

[Published 3/10/10]

EDITOR'S NOTE: For replacement pages for IAC, see IAC Supplement 3/10/10.